

April 16, 2024

**ADDENDUM #2**

TO ALL PROSPECTIVE BIDDERS:

SUBJECT: Automatic Temperature Control System Replacement at Quander Road Center  
(MMB-064-24)

BID OPENING DATE: (ORIGINAL DATE) April 23, 2024, at 10:00 AM

THE SUBJECT INVITATION FOR BID IS AMENDED AS FOLLOWS:

*THIS ADDENDUM IS SUPPLEMENTARY TO THE PLANS AND SPECIFICATIONS FOR THE ABOVE SUBJECT REQUIREMENT. ALL CHANGES, ADDITIONS AND DELETIONS SHALL BECOME PART OF THE CONTRACT.*

**CLARIFICATION:** The following item is provided as clarification:

**Bray valve actuators** are approved for Control Valves Only as part of BAS Master Specification, Section **5.05.B.11**.

**Damper actuators**, as listed in BAS Master Specification Section **5.08.B.g** pertains only to damper actuators and does not apply to brands approved for control valves. Bray is NOT approved for Damper Actuators.

***All other terms and conditions remain unchanged.***



Angela C. Mylechraine, Contracts Administrator  
Office of Administrative Services

THIS ADDENDUM IS ACKNOWLEDGED AND IS CONSIDERED A PART OF THE SUBJECT INVITATION FOR BID.

SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

NAME OF FIRM: \_\_\_\_\_

A SIGNED COPY MAY BE RETURNED PRIOR TO BID OPENING OR MAY ACCOMPANY YOUR BID.